



REQUEST FOR BOARD ACTION

ITEM NO. 15.

DATE OF MEETING: October 7, 2013

REQUESTED BY: Michael G. Mack, Utilities Director

SHORT TITLE: Resolution by the Board of Directors of the Rocky Point/Topsail Water and Sewer District Approving the Award of the Bid for the Rehabilitation of the Regional Sewer Lift Station in Rocky Point to Dun-Right Services, Inc. of Florence, South Carolina in the Amount of \$17,876 and Authorizing the Issuance of the Purchase Order for the Project.

BACKGROUND: After ten years of industrial sewer use by Del Labs/Coty and 23 other institutional and commercial customers, hydrogen sulfide has substantially eroded the concrete interior walls of the regional sewer lift station. This is a normal occurrence when high strength industrial waste is pumped into a concrete wetwell structure. If not repaired, the wetwell will begin to suffer structural weakness beyond the surface area and a major repair or replacement would be inevitable. Staff researched the available products to repair and restore the wetwell to its original condition and then seal the wetwell to prevent degradation in the future. Proposals were sought from five contractors and staff received three. The best product and price was provided by Dun-Right Services, Inc. of Florence, South Carolina. Staff is recommending award of the rehabilitation bid to Dun-Right. A Bid Tabulation is provided for review and consideration of award.

SPECIFIC ACTION REQUESTED: To consider a resolution to approve a Lump Sum Proposal from Dun-Right Services, Inc. of Florence, South Carolina and authorize the execution of a contract and issuance of a Purchase Order in the amount of \$17,876 to Dun-Right Services, Inc. for the rehabilitation of the regional sewer lift station in Rocky Point.

COUNTY MANAGER'S RECOMMENDATION

Respectfully recommend approval.



Initial

RESOLUTION

NOW, THEREFORE BE IT RESOLVED by the Board of Directors of the Rocky Point/Topsail Water and Sewer District:

the Lump Sum proposal from Dun-Right Services, Inc. for the rehabilitation of the regional sewer lift station in Rocky Point is hereby approved and the issuance of a contract and Purchase Order in the amount of \$17,876 is authorized. The Chairman/County Manager is authorized to execute any/all documents necessary to implement this resolution.

AMENDMENTS:

MOVED _____ SECONDED _____

APPROVED _____ DENIED _____ UNANIMOUS _____

YEA VOTES: Brown ___ McCoy ___ Tate ___ Ward ___ Williams ___

George R. Brown, Chairman 10/07/13
Date

ATTEST 10/07/13
Date

PENDER COUNTY UTILITIES

**Regional Sewer Lift Station Rehabilitation
Proposal Evaluation**

	ARM Environmental Services, Inc.	Commonwealth Epoxy Coatings, Inc.	Dun-Right Services, Inc.
	Florence, SC 29501	Newport News, VA	Florence, SC
	License: NC	License: NC	License: NC
Description	Base Bid Amount	Base Bid Amount	Base Bid Amount
Proposal Cost	\$ 19,264.00	\$ 27,120	\$ 17,161.00
Repair Method	Sewpercoat	Tnemec 217 Repair Mortar, and Tnemec Permashield Lining Series 434/435 @ 125 mils	1.5" Mortar Base, 125 Mil Epoxy Top Coat by Raven Systems
Preparation	5,000 psi blast, Mortar Patch, Polyurethane Injection Grout	Pressure Water Blast, and Sandblast	5,000 psi blast
Additional Costs	\$ 1,830.00 for Coating Prepared DIP with 2 coats Polyurethane	Pipe Coating Included	\$ 715.00 to top coat new DIP with Raven System
Contact	Len Hutchinson lhutchinson@armenv.com	Jeff White/Joseph Saleeby jwhite@commonwealthe Epoxy.com	Tim Carter/Gregg Davis dunrightinc@bellsouth.net
TOTAL BID	\$ 21,094.00	\$ 27,120.00	\$ 17,876.00